

Addendum LEC Water Heater Replacement 8-20-2024

Is an IP or MSTP connections being provided off the BACnet controls?

References on Company letter head.

Indicate Overhead and Profit % on any change orders on Company letterhead.

Circulation pumps to be lowered from ceiling to more convenient location to work on preferably on back wall behind current water heaters.

New circ setters should be plumbed in when circ pumps are moved.

Existing expansion tanks will be reused and piped into new water heaters.

Existing supply and return piping is 3" copper.

5 psi gas comes into the building at the regulator.

Existing gas regulators will be reused where needed.

Intake and exhaust piping can be routed through existing roof penetrations.