

## **UW Platteville Baraboo – Sauk County AC Replacement Addendum**

**(1) Page 1 of the RFB, section II: The Public Opening of Bids is amended as follows:**

Public Opening of Bid will be conducted at the Sauk County Courthouse – EMBS Meeting Room at 10:10 a.m.

**(2) Can we use the existing piping?**

Yes, the existing piping can be re-used if it is cleaned properly from one refrigerant to another.